

Approved Body No. 1224

Certificate of Constancy of Performance

1224-CPR-1212

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product

Fire Resisting Doorsets

Intended for use in fire and/or smoke compartmentation and/or escape routes

Placed on the Market under the Name of

**Sentry Doors Ltd
Brooklands Road
Carcroft
Doncaster
DN6 7BA
UNITED KINGDOM**

and produced in the manufacturing plant

Sentry Doors Ltd, Brooklands Road, Carcroft, Doncaster, DN6 7BA, United Kingdom

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s)

EN 16034: 2014

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 22/01/2021 and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

Date of Initial Certification: **22/01/2021**

Date of Last Issue: **13/10/2025**

Date of Expiry: **08/08/2028**



Natasha Bambridge
(Divisional Director)
For and on behalf of Element

Scope of Certification

Stredor 44 E30 FED

Product: Fire Resisting External Pedestrian Doorsets covered by EN 14351-1:2006+A2:2016
Intended use: Fire Compartmentation and/or escape routes

Essential characteristics	Performance	Harmonized technical specification
Resistance to Fire	E15, E20,E30	EN 16034:2014
Smoke control (only for applications where limitation of smoke is required)	Sa	
Ability to release	NPD	
Self-Closing (only for self-closing fire resistance and/or smoke control doorsets and/or openable windows)	NPD	
Durability of ability to release	NPD	
Durability of self-closing	NPD	